



Product Registration Certificate

Printed on: 28 Oct 2014

Registration No. 3067
Title Wall Mounted Automatic Transfer Switch Panel
Status Authorised For Use
Supersedes ProductID N/A
Superseded By ProductID N/A
Date Authorised for Use 24 Oct 2014
Primary Use Wall mounted automatic transfer switch panels, 3 phase, 400/230VAC, 50Hz, 4 pole, IP54, incorporating 125A – 630A Socomec motorised interlocked changeover switch disconnectors and control relay with local digital display. Conditional s/c rating 50kA, to BS EN 61439-2.
Additional Info/KeyWords Not tested for compliance with LU Standard 1-085 'Fire Safety Performance of Materials' but can be used when installed in an hour fire rated room, with smoke detection and <75m3. Manufacturer A F Switchgear Limited Nunn Brook Road Sutton-in-Ashfield Nottinghamshire NG17 2HU England Telephone: 01623-555600 Fax: 01623-555800 www.afswitchgear.co.uk e-mail@afswitchgear.co.uk
Classification Hierarchy Electrical
 Stn Lighting & Pwr AC Only
Manufactured By AF Switchgear Ltd.

Requirements

ReqID	Requirement	Status	Trial
No records to display.			

Conditions

Description	Linked To ReqID
Not tested for compliance with LU Standard 1-085 'Fire Safety Performance of Materials' but can be used when installed in an hour fire rated room, with smoke detection and <75m3.	

Evidence

EvidenceText	EvidenceType	FileName	Linked To ReqID
	Test report	FTS001-02-Issue 13-WORKS Final Test-Insp Cert-030713.pdf	
	Test report	TS001-WD-Issue 21-Final Inspection Test Standard-101013.pdf	
	Installation Instructions / Guidelines	WI09-Issue 8-Site Installation Work Procedures-060114.pdf	
Genral Arrangement	Drawing	900-07942-009-1-01A Layout (1).pdf	
Schematic	Drawing	900-07942-009-2-01 -01 (1).pdf	

Reminder: Products must not be publicised as being authorised for use by London Underground Limited (LUL) without also stating any conditions or limitations that apply, nor may any LUL intellectual property rights (such as the roundel trademark) be used in any such publicity. LUL reserves the right to withdraw authorisation of any product publicised in breach of this reminder. Refer to Web site www.lu-apr.co.uk to check current status, download attachments and for details of other products.

MAYOR OF LONDON